
Exova Warringtonapt Key Industrial Park Fernside Road Willenhall West Midlands WV13 3YA T:+44 (0) 1902 722 122 F:+44 (0) 1902 727 242 E: willenhall@exova.com W: www.exova.com



EN 12051:1999



TESTS OF DOOR AND WINDOW BOLTS

A Report To: Eurolever Architectural Hardware Ltd

Document Reference: 304455

Date: 02 August 2011

Copy: 1

Issue No.: 1

Page 1







TEST CONCLUSIONS

Samples of:

Manufacturer Eurolever Architectural Hardware Ltd

Product Flush Bolt Model SS1932

have been tested in accordance with: EN12051:1999 Building Hardware-Door and Window Bolts

by Exova Warringtonapt [a UKAS accredited Testing Laboratory (No. 0621).and EC Notified Body

number 1104]

At Key Industrial Park, Fernside Rd., Willenhall, West Midlands. WV13 3YA.

Results as detailed below:

Clause No.	e No. Description		
4.1	Category of Use-Grade 3	Yes	
4.2	Number of test cycles-Grade 3	Yes	
4.4	Fire Safety-Grade 1	Yes	
4.5	Safety in Use-Grade 1	Yes	
4.5.1	Operation against a moderate side load-Grade 1	Yes	
4.5.2	Operation after a heavy side load-Grade 1	Yes	
4.6	Corrosion Resistance-Grade 2	Yes	
4.6.1	Protection requirement	Yes	
4.6.2	Test requirement	Yes	
4.7	Security-Grade 1	Yes	
4.7.1	Resisatnce to end load-Grade 1	Yes	
4.7.2	Resulting projection-Grade 1	Yes	
4.7.3	Resistance to sawing-Grade 1	N/a	
4.7.4	Resistance to side load-Grade 3	Yes	

Classification achieved

Category of duty	Number Of test cycles	Test door mass	Fire resistance	Safety In use	Corrosion resistance	Security
3	3	<u>-</u>	1	1	2	1

No inferences can be made regarding performance against other requirements of this standard

NOTE.

These tests are not covered by the Laboratory UKAS accreditation schedule.

Tests marked "NA" are not applicable to the type of device under test.

Tests marked "NT" not be applied to the device under test.

Document No.:

304455

Page No.:

2 of 14

Author:

I keeling

Issue Date:

2 August 2011

Client:

Eurolever

Issue No.:

1



AUTHORISATION

Tests performed	d bv:	lan Keeling.	Operations	Manager
-----------------	-------	--------------	------------	---------

Report issued by: Ian Keeling, Operations Manager

Signed a Lack

02 August 2011 Date

For and on behalf of Exova Warringtonapt

Report authorised by: Steve Wilkes, Deputy Operations Manager

Date 02 August 2011

For and on behalf of Exova Warringtonapt

Report issued: 02 August 2011

NOTE.

These tests are not covered by the Laboratory UKAS accreditation schedule.

Tests marked NT were not tested

Tests marked NA are not applicable to the product on test.

The laboratory has tested the products supplied by the client as sampled in accordance with their own requirements

Exova Warringtonapt is an EC Notified Body Number 1104

This report shall not be reproduced except in full, (and then only as permitted by copyright laws), without written approval from Exova Warringtonapt

Document No.: 304455

Page No.:

3 of 14

Author:

I keeling

Issue Date:

2 August 2011

Client:

Eurolever

Issue No.:

1