

Exova Warringtonapt
Key Industrial Park
Fernside Road
Willenhall
West Midlands
WV13 3YA

T : +44 (0) 1902 722 122
F : +44 (0) 1902 727 242
E : willemhall@exova.com
W: www.exova.com




Report No: 303286a

BS 8424 BUILDING HARDWARE-PULL HANDLES

Assessment of:
Eurolever Monte Carlo Collection
Ref 1200,
Pull Handles (380mm Length)

Tested to: BS8424:2004

For: Eurolever Architectural
Hardware Limited
2 Charles Street
London
W1J 5DE



Assessment of: Eurolever Monte Carlo Collection Ref 1200, Pull Handles (380mm Length)

A Report To: Eurolever Architectural Hardware Ltd

Document Reference: 303286a

Testing
Advising
Assuring



0621

TEST CONCLUSIONS

Samples of: Pull Handles
Product: Eurolever Monte Carlo Collection Ref 1200 Pull Handles
Manufactured by: Eurolever Architectural Hardware Limited
Model: Ref 1200
Size: 380mm x 25mm x 75mm
have been assessed in accordance with: BS8424:2004

By Exova Warringtonapt Laboratories Ltd.
At Key Industrial Park, Fernside Rd., Willenhall, West Midlands. WV13 3YA,

Results as detailed below:

Clause No.	Description	Compliance
7.3.3.2	Durability handles less than 200 mm long	N/a
7.3.3.3	Durability handles more than 200 mm long	Yes
4.7	Corrosion resistance Grade 4	Yes

All results contained in this report were assessed from report number 303286

No inferences can be made regarding performance against other requirements of this standard

AUTHORISATION

Tests performed by: Alan Fairfield – Test Engineer
Report issued by: Alan Fairfield – Test Engineer Signed  Date 24th March 2011 For and on behalf of Exova Warringtonapt
Report authorised by: Ian Keeling – Operations Manager Signed  Date 24th March 2011 For and on behalf of Exova Warringtonapt
Report issued: 24th March 2011



0621

NOTE.
Tests marked "Not UKAS Accredited" are not covered by the Laboratory UKAS accreditation schedule.

Tests marked NT were not tested

Tests marked NA are not applicable to the product on test.

The laboratory has tested the product supplied by the client as sampled in accordance with their own requirements

Exova Warringtonapt is an EC Notified Body Number 1104

This report shall not be reproduced except in full, (and then only as permitted by copyright laws), without written approval from Exova Warringtonapt

